GOVERNMENT OF ANDHRA PRADESH
ABSTRACT

Water Resources Department- Permission to draw water from Guntur Channel to NRI Academy of Science Medical college & Hospital at Chinakakani, Mangalagiri Mandal in Guntur District to a tune of 5,00,000 litres per day (0.20cusecs) i.e 0.0047 TMC from Guntur Channel during the canal running period of 9 months- Permission-Accorded.

WATER RESOURCES (WRG-GRC) DEPARTMENT

G.O.RT.No. 546 Dated: 10-12-2019

Read the following:

1) From the President, NRI Academy of Sciences Science, Medical College& Hospital, Chinakakani, Guntur District, dated:16.02.2019.
2) From the Engineer-in-Chief (Irr), Water Resources Department, Vijayawada, Lr.No.ENC(I)/DCEDW/OT7/AEE20/NRI Academy/2016, dated:15.10.2019.

@@@@

ORDER:

In the reference 1st read above, the President, NRI Academy of Sciences, Science Medical College and Hospital, Chinakakani, Guntur Districts has requesting to **accord permission to draw 5,00,000 litre/day of water from the Guntur Channel** to mitigate the drinking water needs of the patients and staff approaching the Hospital for treatment. He has stated that the patients, visitors and staff belong mostly to the Mangalagiri and from all over the parts of the District.

2. In the reference 2nd read above, the Engineer-in-Chief (Irr), Vijayawada has submitted a detailed report and requested the Government to accord permission to draw water from Guntur Channel to NRI Academy of Science Medical College & Hospital at Chinakakani, Mangalagiri Mandal, Guntur District to a tune of 5,00,000 litres per day (0.20cusecs) i.e 0.0047 TMC from Guntur Channel during the canal running period of 9 months subject to terms and conditions as a special case.

3. After careful examination of the matter, Government hereby accord permission to draw water from Guntur Channel to NRI Academy of Science Medical college & Hospital at Chinakakani, Mangalagiri Mandal in Guntur District to a tune of 5,00,000 litres per day (0.20cusecs) i.e 0.0047 TMC from Guntur Channel during the canal running period of 9 months, subject to the following terms and conditions;

1. The firm NRI-Academy of Science Medical College Hospital, Chinakakani(V), Mangalagiri Mandal, Guntur District shall not have any right to draw water without permission of the department.
2. The water drawn from the Source should be utilized for the purpose for which permission is granted.
3. The consumptive utilization calculated per day fixed by the Department should not exceed under any circumstances.
4. The firm cannot claim the permission as a right at the cost of irrigation.
5. The firm can draw water only as and when there is sufficient flows available in canal, without effecting the irrigation and drinking water demand on any existing or proposed projects already.
6. The cost of construction of pipe line and other infrastructure should be borne by the firm duly acquiring the necessary land etc., at their own cost.
7. The water rates payable shall be as levied by the Government as per the norm of Industrial usage supply from time to time.
8. A detailed plan showing the location of intake arrangements, pump house, alignment of pipe line and conveyance system should be furnished to the department, for approval.
9. Pump house should be constructed away from the Channel bund.

10. Off Take sluice should be constructed as per the norms of Water Resources Department and banks should be protected with wing walls and banks should be constructed with proper consolidation under the supervision of the Departmental officers.
11. The sill level of Intake pipeline should be fixed above 1/2 FSL of the canal.
12. Water measuring devices should be placed at the off take point and proper locking arrangements and shuttering arrangements must be made with their own cost under the supervision of the Water Resources Department.
13. Digital Water meters and measuring devices should be installed at the pump house by the industry at their own cost to measure the water consumed and should be made available to the Water Resources and Revenue Department authorities at all times for inspection.
14. The operation of Off-Take sluice shall be under the control of Water Resources Department only.
15. Water supply will be stopped when there is lean flows in the channel.
16. The water charges are to be paid in advance for the year on Demand as per the rate fixed by the Government.
17. The firm should be given an undertaking that they will not raise any legal Complications for not supplying of water during the drought period, short fall rains and any type of unforeseen problems.
18. The firm should make its own arrangements for sufficient storage of water during non supply period.
19. The Water Resources Department is no way responsible for non supply of water due to any reasons.
20. The Department is no way responsible for any damages that may occur to the off take house during floods.
21. This Department is not responsible for any dispute that arises with neighboring industries and public and any legal matters.
22. The firm should not create any objection for improvement/Modernization works to the said Reservoir in future, and they have to relocate the pumps if necessary, with their own cost.
23. The Water Resources Department reserves the right for cancellation of the permission without assigning any reasons thereof.
24. The designs approved by the Chief Engineer, CDO.
25. The rates would be as per industrial usage.

4. The Engineer-in-Chief (Irr), Water Resources Department, Vijayawada shall take necessary further action in the matter.

(BY ORDER AND IN THE NAME OF THE GOVERNOR OF ANDHRA PRADESH)

ADITYA NATH DAS
Special Chief Secretary to Government

To
The Engineer-in-Chief (Irr), Water Resources Department, Vijayawada.
Copy to :
The P.S to Hon'ble Minister for Water Resources Department.
The P.S to Spl. Chief Secretary to Government, Water Resources Department
SF/SC.

//FORWARDED :: BY ORDER//

SECTION OFFICER